Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:22 pm

PWS ID: UTAH18055 ***Name:*** MT HAVEN OWNERS ASSOCIATION

Legal Contact MT. HAVEN OWNERS ASSN.
STEVE HOSKINS

Address: 8122 S 1715 E
SANDY, UT 84093

Phone Number: 801-944-0881

City Served (Area):

County: SALT LAKE COUNTY

Rating: Approved

Rating Date: 04/09/1996

Activity Status: Active

System Type: Non-community

Activity Status Cd: Active

Population: 85

Last Inv Update: 03/11/2010

Last Snty Srv Dt: 09/02/2010

Surveyor: SHAWN GONZALES

Oper Period: 6/1 to 10/15

	Gal/Day	Gal/Min
Avg Daily Prod:		
Total Dsgn Cap:		
Total Emerg Cap:		

Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	HOSKINS, STEVE		801-944-0881		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	39
			39 Total Svc Connections

Storage

Total Storage: 20,000 GAL ***Number of Units:*** 2 ***Adequate Capacity:*** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	10,000 GAL	Steel		A	
ST002	STORAGE FACILITY ST002	Ground	10,000 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	MT. HAVEN SPRNG	Active	SP				Yes	GW	Seasonal	6/1 to 10/15	

**Reports measured flow for wells, approved design capacity for all other sources.*